



Document No. CA061

Version 4.0 July 2000

Refer to Certifire Pty.

Ltd. to confirm current issue status

LIGHT WEIGHT FIRE RESISTANT PARTITIONS

PO Box 6825
St Kilda Road Central Vic 8008
Tel: +61 3 9865 8644
Fax: +61 3 9865 8615
www.certifire.com.au
info@certifire.com.au

1. SCOPE AND DEFINITIONS

1.1 Scope

1.1.1. This document sets out the general operating procedures and performance, quality assurance and training requirements for the Certifire Australia Scheme for light weight fire resistant partitions.

1.1.2 Reference should also be made to the following Certifire Schedules:

- a) Certifire Australia procedures & regulations **CA001**
- b) Certifire Australia Quality Assessment Schedule (QAS) for Manufacturers/Suppliers and Installers **CA002**

1.2 Definitions

Certifire Schedule – A document setting out requirements and procedures of the Certifire Australia Schemes.

Certifire Specification - A form of words for nominating the Certifire Schemes for building projects.

Certifire Scheme - A third party certification scheme for the purpose of listing suppliers and contractors which comply with the relevant Certifire Schedules.

BCA - The current edition of the Building Code of Australia.

Appraisal - In the context of the Certifire Scheme an appraisal is an assessment of a system against the requirements of the appropriate Certifire Schedules.

Fire Resistance Level (FRL) - The grading periods in minutes determined by a fire resistance test defined in the BCA for

- a) Structural adequacy;
- b) Integrity; and
- c) Insulation

and expressed in that order. A dash, for example means there is no requirement for an FRL criterion.

2. GENERAL OPERATING PROCEDURES

2.1 Introduction

2.1.1 The objective of the Certifire Australia Scheme with respect to light weight fire resistant partitions is to increase the likelihood that the partitions when installed in buildings would be capable of achieving nominated FRLs. This is to be achieved through:

- The independent appraisal of products in a consistent manner against clearly defined performance requirements;
- The appraisal of the competency and capability of fire protection contractors to install fire stopping systems correctly against documented standards;
- The definition of minimum quality assurance requirements for product suppliers and fire protection contractors, and independent auditing of companies to monitor on-going compliance with these requirements;
- The preparation of certificates defining the performance of fire protection systems or the capabilities of fire protection contractors in a consistent manner;
- Clear unambiguous labelling requirements for systems supplied and installed in accordance with the scheme.

2.1.2 It is recognised that the size and type of project and geographic location of a site can influence the selection of an appropriate Certifire specification.

2.1.3 For most major building projects in Australia the standard Certifire specification should be nominated which suggests that Certifire listed products be installed and maintained by contractors listed by Certifire or equivalent schemes. The Certifire Scheme covers the supply and installation phases in an accountable and cost-effective manner, and enables the installation to carry a Certifire label. An example of the Certifire label for penetration seals is shown in Appendix 2.

2.1.4 Other options under the Certifire scheme are

- Product only certification, and
- Independent site inspection.

It should be recognised that product only certification does not provide any control over site installations and therefore should only be specified when installation by a Certifire contractor is impractical. Independent site inspection, if used in conjunction with a Certifire contractor, can provide additional control but also adds significantly to costs in quality control during the installation phase since an inspector will be unlikely to be on site at all times and cannot verify all details.

Independent site inspection will not be cost-effective for most applications. See Appendix 3 for examples of typical specifications for the Certifire Scheme.

2.1.5 The ability of fire protection systems to sustain the Fire Resistance Level (FRL) of light weight fire resistant partitions is dependent upon many factors. Typically these include variations in the components/ materials of fire protection systems, variations in the penetrating services and separating elements and variations in installation methods. Reference should be made to Certifire Schedule CA021 for further details.

- 2.1.6 The methods for appraisal light weight fire resistant partitions are given in section 3; the quality assurance level requirements for the manufacturers and suppliers of the systems are given in section 4; the competency/ training levels required for key personnel of a fire protection contracting organisation installing and maintaining light weight fire resistant partitions are given in section 5; and the quality assessment requirements for these fire protection contractors are given in section 6.

2.2 Compliance with Building Regulations

- 2.2.1 It is the intention that the Certifire scheme will complement relevant building regulations by ensuring systems are in place to demonstrate compliance with relevant regulations.

- 2.2.2 The Building Code of Australia 1996 (BCA 96) allows building solutions which either comply with the deemed-to-satisfy provisions, are equivalent to the deemed-to-satisfy provisions, or comply with the nominated performance requirements.

The deemed-to-satisfy provisions prescribe, among other things, fire resistance levels (FRLs) and smoke resistance properties required by certain construction elements in buildings. Certifire certificates can be used to check compliance with those provisions. However, when a building solution is to be assessed for either equivalence to the deemed-to-satisfy provisions, or for compliance with the performance requirements, data from Certifire certificates will need to be considered on a case-by-case basis.

- 2.2.3 If the building regulations and Certifire scheme documents conflict, the building regulations must take priority but the manufacturer or fire protection contractor must notify Certifire in writing of any variations from the scope of their certification required by the regulations.

- 2.2.4 In some instances the regulatory authority having jurisdiction may permit the installation of systems which lie outside the scope of the current Certifire listing. Under these circumstances the contractor must:

- a) Not attach a Certifire label, or
- b) If a Certifire label is to be applied, supply written proof to Certifire from the relevant regulatory authorities that the installation is 'approved' together with an appropriate fee to Certifire. Certifire will then maintain a file on the project so that any queries in the future can be answered.

2.3 Labelling and Log Books

- 2.3.1 The use of Certifire labels is strictly controlled to enable the status of an installation to be clearly identified.

- 2.3.2 The packaging of component parts and materials that form part of a Certifire listed system can incorporate the Certifire logo as indicated in Appendix 2 providing the scope of the appropriate Certifire certificates is clearly defined in the instructions supplied. The components of a system cannot be labelled prior to installation.

- 2.3.3 An installation can be labelled with a Certifire label if the installation complies with a current Certifire certificate and it has been installed by a Certifire listed fire protection contractor within the scope of the contractor's certification or it has been attached on the basis of the procedures indicated in clause 3.3.3.

- 2.3.4 The Certifire labels are available from Certifire Pty. Ltd. in numbered batches. The Fire Protection Contractor shall keep a register of the location of all Certifire labels that have been attached to installations
- 2.3.5 A log book listing all relevant walls must be supplied by the fire protection contractor to the building owner or representative. The fire protection contractor must retain a copy for a minimum of ten years. The log book shall include a listing of the Certifire labels applied and reference to the relevant Certifire Product Certificates and comply with the requirements of the relevant Australian Standard.
- 2.3.6 Copies of the Certifire Schedules and certificates relevant to the installation shall be attached to the log book. Members of the Certifire Scheme are granted permission to copy Certifire schedules specifically for this purpose.

3. CERTIFIRE REQUIREMENTS FOR LIGHT WEIGHT FIRE RESISTANT PARTITIONS

3.1 Building Regulations and Standards

- 3.1.1 Systems are to be appraised against the requirements of the current Australian Building Regulations as defined in the Building Code of Australia.
- 3.1.2 The BCA 1996 CP1, CP2 & CP4 states that a building must have elements which will to the degree necessary maintain structures stability during a fire, avoid the spread of fire within and between buildings and limit the generation and spread of heat and toxic gases.
- 3.1.3 The BCA 1996 specification A2.3 2(b) states that the FRL of a building element will be equal to that achieved by an identical prototype submitted to the Standard Fire Tests (AS1530.4 - 1990) conducted by and confirmed in a report from a Registered Testing Authority.

The BCA 1996 specification A2.3 2(c) allows the Registered Testing Authority to assess minor differences from the tested prototype, and detailed in a report from the Registered Testing Authority.

- 3.1.4 Appraisals shall be performed by registered testing authorities using the methods defined in the above standards and/or documents.

3.2 Systems based on tested prototypes

- 3.2.1 Appraisals will be based on information derived from tests carried out in accordance with the heating conditions of AS1530.4.
- 3.2.2 The appraisals will be based on test data from a testing authority registered by the National Association of Testing Authorities (NATA) to test in the relevant field, or
an organisation outside Australia recognised by NATA through a mutual recognition agreement, or
other organisations defined as Registered Testing Authorities in the BCA.
- 3.2.3 Fire tests carried out to standards other than the current edition of AS1530.4 will only be used if confirmatory data (an opinion from a registered testing authority) is available to demonstrate the continued applicability of the data and if the test methodology is sufficiently similar to that specified in the current edition of AS1530.4.

Note: It is not the intention that all tests are required to be repeated as new editions of AS1530.4 are released. In many cases it may be acceptable for evidence from tests used to extend the range of application to also provide confirmatory data. It is important that Certifire is notified during the planning stages of such a test to ensure the test data will be acceptable. Where significant changes to a test methodology occur which necessitate further testing of existing Certifire systems a 'grace period' of 12 months will be permitted which will only be extended if further delays are justifiable. The 'grace period' does not apply to systems that have been demonstrated not to comply with the current Certifire specifications.

3.3 Variations from the Tested Prototype

- 3.3.1 The appraisal will define the field of application for the system based on a prototype test, and
- a) Assessments/opinions issued by a registered testing authority complying with the technical requirements of the BCA 1996
 - b) Assessments/opinions shall be based on engineering principles and where appropriate be supported by calculations to supplement test data.
- 3.3.2 The certificate must list all test data and assessments which were used in the appraisal.
- 3.3.3 A Certifire label/mark must not be applied to any system which does not comply with the requirements of a current Certifire certificate unless written proof from the relevant regulatory authorities that the installation is approved is lodged with Certifire together with a lodgement fee and the system is installed by a Certifire listed fire protection contractor.

Certifire will then maintain a file on the project for a minimum of ten years so that any queries in the future can be answered.

3.4 Appraisals

- 3.4.1 Three alternative methods are available for the preparation of an appraisal for each system. These are given in clauses 3.4.2 to 3.4.4.
- 3.4.2 The simplest appraisal will be that of a single system without variations based on one fire test. The test data, and a specification of the test assembly, manufacturers installation instructions, and physical test data if appropriate is submitted to Certifire for appraisal and preparation of a certificate.
- 3.4.3 A manufacturer may submit a range of tests and opinions/assessments for variations from the tested prototype from registered testing authorities meeting the requirements of this schedule. The assessments/opinions must comply with the technical requirements of the BCA and this schedule.

In addition, drawings and specifications of the prototypes and variations together with manufacturer's installation instructions must be submitted with supplementary test data if appropriate (eg. elasticity tests).

Certifire will then prepare an appraisal and certificate for each system.

- 3.4.4 A manufacturer may obtain an appraisal against the relevant Certifire standards by a registered testing authority as defined in clause 3.2.2 of this schedule. The appraisal, together with all supporting data, must be submitted for review by Certifire and a certificate for each system will be issued that the appraisal complies with the appropriate Certifire Schedules.

3.5 Installation

- 3.5.1 Installation must be in accordance with the tested prototype and best industry practice.

3.6 Serviceability

- 3.6.1 The certificate may include data on the durability/serviceability of a system.
The certificate shall describe the test methods used and report results obtained.
If no data is available the certificate shall state, for example, "No data is available"
- 3.6.2 A statement will be included on each certificate that the system should be selected to suit the particular environment or application.

4. CERTIFIRE QUALITY ASSURANCE REQUIREMENTS FOR MANUFACTURE AND SUPPLY OF LIGHT WEIGHT FIRE RESISTANT PARTITIONS

4.1 General Requirements

- 4.1.1 In addition to the requirements of this schedule, the Manufacturer must operate a quality system which complies with either:

- a) AS/NZS/ISO9002, or
- b) Certifire - Quality Assessment Schedule CA002

Note: It will eventually become a requirement for all manufacturers to comply with AS/NZS/ISO9002 and the Certifire Quality Assessment schedule will be phased out. The time of the phase out will be determined by the relevant sub-committee and Certifire Advisory Panel.

- 4.1.2 The quality system will be initially audited by Certifire. Annual audits are to be carried out by Certifire or by a JASANZ accredited independent organisation that will exchange information with Certifire where an AS3902 quality system is in operation.
- 4.1.3 Additional audits required to investigate complaints against a manufacturer are to be carried out by Certifire.

4.2 Specific Requirements for Light Weight Fire Resistant Partitions

General

- 4.2.1 A quality system for a manufacturer or supplier of light weight fire resistant partitions and components must specifically address the requirements given in the remainder of this section.
- 4.2.2 The materials and components that are supplied as light weight fire resistant partitions are diverse and include but are not limited to:
- Solid systems;
 - Steel/timber members;
 - Plaster based systems;
 - Vermiculite boards;
 - Calcium silicate boards;
 - Mineral fibre boards;
 - Fixings

- 4.2.3 Because of the diversity described above the requirements of this section are provided in general terms.

Specifications and instructions for manufacture

- 4.2.4 The quality system shall include documented specifications and manufacturing instructions for each type of component and assembly.

- 4.2.5 These specifications must be clearly referenced to:

- a) The tested prototype, and
- b) Where relevant any permissible variations supported by assessments from registered testing authorities, and
- c) The Certifire certificate

- 4.2.6 The specification must accurately describe:

- a) All materials used in the manufacture of a component material or assembly including tolerances, source and any performance requirements
- b) Ordering details
- c) Methods of storage
- d) Tests and inspections and procedures in case of non-compliance

- 4.2.7 It is preferred that all materials and components are supplied and manufactured by companies under third party quality assurance schemes. However it is realised that in many instances this may be impractical (eg. screw fixings).

Third party Suppliers

- 4.2.8 Many systems are manufactured from materials whose properties may vary considerably and significantly affect the fire resistance performance of a system. It is therefore important that the Quality system monitors the sources and critical parameters of all materials to ensure that raw materials when compounded will meet fully the requirements of the performance specification of each product.

- 4.2.9 In some instances components may be delivered direct to site. Documented procedures shall be provided for the inspection under these circumstances. The installer may carry this out.

- 4.2.10 The manufacturing instructions shall describe all processes in detail together with inspection procedures. Manufacturing tolerances must be specified together with corrective actions if appropriate and rejection criteria.

Record system

- 4.2.11 The quality system shall be such that a unique number identifies each batch or unit. A record should be kept of the batch number of materials/components supplied by third parties.

- 4.2.12 All material and components used in the manufacture of a batch and inspections and tests during manufacture shall be identified on a file relating to the batch. Where materials are manufactured by a third party to a specification, a certificate of conformance must be obtained and a sample of each batch should be checked and tested following documented procedures.

- 4.2.13 The file on each batch must be retained for a minimum of ten years and be readily identified from the batch numbers marked on the components.

Packaging and instruction

- 4.2.14 The product packaging must be clearly marked with the product designation, batch number and storage conditions. The Certifire mark may be included in accordance with section 2 of this document. Details of the packaging must be submitted to Certifire for approval.
- 4.2.15 Fully documented instructions for the correct installation and use of a product shall be included with each sale. These instructions must be submitted to Certifire and will be referenced in the Certifire certificate.
- 4.2.16 Certifire must be notified prior to any modifications of the packaging or installation instructions and details must be submitted to Certifire for verification prior to publication and that any modifications required by Certifire are incorporated.

Technical services

- 4.2.17 There shall be documented procedures for consulting with and providing advice to customers on the performance and appropriate use of products.
- 4.2.18 The documented procedures shall clearly define the minimum training/competency level requirements for technical advisers and identify the staff members having satisfied these requirements.

Note: A technical adviser should be able to satisfy the competency levels nominated in Section 5 for an installation inspector.

5. COMPETENCY/TRAINING REQUIREMENTS FOR FIRE PROTECTION CONTRACTING ORGANISATION

5.1 General Requirements

- 5.1.1 This section defines the minimum training required by personnel involved in the installation and maintenance of light weight fire resistant partitions.
- 5.1.2 Competency based training methods are adopted with provision to recognize prior learning.
- 5.1.3 Methods for the assessment of the competencies are given together with training requirements where appropriate. It should be noted that a level of competency can be attained by:
- a) Prior knowledge
 - b) On-the-job training/in-house training
 - c) Formal training seminars
 - d) A combination of any of the above

5.2 Key Personnel

- 5.2.1 The key personnel involved in the installation of light weight fire resistant partitions are defined below:

The Project Reviewer

- 5.2.2 The project reviewer may perform the following tasks:
- Review the initial specifications/ drawings / FRLs and where appropriate visit the site;
 - Select appropriate system(s) from Manufacturers Manuals, Certifire certificates and other appropriate materials identifying critical details and any potential non compliances;

- Identify areas where the fire resistance of the barrier could be compromised by service penetrations, doors and the like and provide recommendations;
- Check the proposed systems against the requirements of the BCA and the appropriate Certifire certificate taking appropriate actions if non compliances are identified.

The Project Estimator

5.2.3 The project estimator may perform the following tasks:

- Select appropriate system(s) from Manufacturers Manuals, Certifire certificates and other appropriate materials identifying critical details and any potential non compliances;
- Identify areas where the fire resistance of the barrier could be compromised by service penetrations, doors and the like and provide recommendations;
- Check the proposed systems against the requirements of the BCA and the appropriate Certifire certificate taking appropriate actions if non compliances are identified;
- Order materials and prepare work instructions.

Installer

5.2.4 The installer may perform the following tasks:

- Check materials are undamaged, perform any required tests and comply with the requirements of work instructions;
- Install a system or carry out maintenance work recording batch numbers, carrying out tests/checks as appropriate and identify any variations from the work instructions;

The Inspector

5.2.5 The inspector may perform the following tasks:

- Supervise installation
- Check the final installation/carry out maintenance inspections
- Attach the Certifire mark
- Complete the log book

5.3 Competency Requirements and Assessment Criteria

5.3.1 The key personnel described in section 5.2 shall demonstrate to the satisfaction of Certifire their competency to perform the critical tasks listed below.

5.3.2 The methods of assessment to be adopted by Certifire are summarized below.

5.3.3 The project reviewer/estimator

5.3.3.1 Outcome 1: Identify relevant requirements of the BCA, select the appropriate light weight fire resistant partitions from test reports/Certifire certificates, describe design requirements and check that the system is suitable for its application.

Assessment criterion:

- a) For a given application specify the FRLs required by the BCA

- b) Identify relevant Certifire certificates and/or test data for suitable systems
 - c) List significant design requirements
- 5.3.3.2 Outcome 2: Compare a specification with the requirements of Australian Standard and Certifire certificates, and identify non-compliances. Assessment criterion:
- a) For a specification and nominated Certifire certificate list any variations and non-compliances with the requirements of the BCA and Certifire certificate.
- 5.3.3.3 Outcome 3: Propose a suitable course of action for a specification which does not comply with the requirements of a Certifire certificate.
- Assessment criterion:
- a) For a non-compliant system, identify alternative courses of action.
- 5.3.3.4 Outcome 4: Produce work instructions for the installer and/or orders for materials.
- Assessment criterion:
- a) For a given application prepare work instructions or orders. (Note: Proforma forms can be used)
 - b) Prepare labelled sketches of typical installations if necessary.
- 5.3.3.5 Outcome 5: Interpret engineering drawings and specifications.
- Assessment criterion:
- a) From typical engineering drawings and specifications interpret the information available and identify a suitable system which complies with the requirements of the BCA and the Certifire scheme.
- 5.3.4 Inspector**
- 5.3.4.1 Outcome 1: Identify relevant requirements of the BCA and Certifire certificates for an installation.
- Assessment criterion:
- a) For a given installation, list the relevant requirements of the BCA and Certifire certificate applicable to the installation
- 5.3.4.2 Outcome 2: Inspect installations for compliance with the Certifire certificate and evidence of deterioration.
- Assessment criterion:
- a) For a typical installation carry out an inspection and provide a written statement identifying any non-compliances, etc.
- 5.3.4.3 Outcome 3: Propose a suitable course of action for an installation which does not comply with the Certifire certificate and/or the BCA.
- Assessment criterion:
- a) For a non-compliant system identify suitable rectification works and describe how to implement the courses of action.
- 5.3.4.4 Outcome 4: Complete log book details.
- Assessment criterion:
- a) For a typical project prepare a log book incorporating as a minimum the information listed in clause 2.3 of this Schedule. The log book

must also have provision for recording maintenance inspections. Pro-forma sheets may be used.

5.3.5 **Installer**

5.3.5.1 Outcome 1: Interpret installation instructions.

5.3.5.2 Outcome 2: Perform an installation in accordance with instructions.

Assessment criteria for Outcomes 1 and 2:

Based on written instructions, install a fire protection system following the instructions and the requirements of the relevant Certifire certificate.

Note: Some installers may install only a limited range of systems. Under these circumstances, compliance with the competency standards need only be demonstrated for the relevant systems.

5.3.5.3 Outcome 3: Identify variations from installation instructions and the Certifire certificates, taking appropriate action.

Assessment criterion:

a) For a given installation identify any variations from installation instructions and Certifire certificates and describe suitable actions.

5.4 **Assessment of Training and Competency**

5.4.1 Evidence of the training and competency of key personnel shall be provided prior to the initial audit. This can take the form of examples of work, or results from assessments from training programmes. The roles of all members of staff must be defined in a Quality Manual for the organisation together with training requirements.

5.4.2 Certifire will review the information. The initial audit will assess the competency of key staff members, using the criteria given in section 3 of this schedule.

5.4.3 The audit will also assess the suitability of current training methods for the Applicant Company.

6. **CERTIFIRE QUALITY ASSURANCE REQUIREMENTS FOR FIRE PROTECTION CONTRACTORS**

6.1 **General Requirements**

6.1.1 The contractor must operate a quality system which complies with the Certifire Quality Assessment Schedule CA002. CA002 is the minimum acceptable level for Quality Assessment.

Note: It may become a requirement for all installers to comply with AS3902. The timing and decision to phase out the Certifire schedule CA002 will be determined by the relevant Certifire Technical Sub-committee and Certifire Advisory Panel.

6.1.2 The quality system will be initially audited by Certifire. Annual audits are to be carried out by Certifire or by a JASANZ accredited independent organisation that will exchange information with Certifire where an AS3902 quality system is in operation.

6.1.3 Additional audits required to investigate complaints against a manufacturer are to be carried out by Certifire.

6.2 Specific Requirements for the Installation of Light Weight Fire Resistant Partitions

6.2.1 A quality system for an installation contractor must specifically address the requirements given in the remainder of this section.

Review of tender specifications, enquiries and orders

6.2.2 All tender documents and orders shall be reviewed by suitably trained and competent personnel for:

- a) Compliance with Certifire certificates relevant to the installation;
- b) Compliance with the requirements of the BCA;
- c) The ability of the manufacturer to perform the work on time;
- d) The suitability of a system for its particular application.

6.2.3 The review should include but not necessarily be limited to checks on:

- a) Material composition & thickness
- b) existing construction
- c) FRL
- d) The serviceability of the system

6.2.4 Written procedures for actions required if a non-compliance is identified shall be provided.

Specifications and instructions

6.2.5 The quality system shall include documented specifications for ordering materials/components, checks for compliance with the specifications, recording batch numbers, storage of materials, etc.

6.2.6 The quality system shall require that no claims in relation to Certifire or Certifire membership are made for the installation of systems which do not comply with the requirements of a current Certifire certificate. Documented procedures shall be included defining the use of the Certifire logo and claims of Certifire membership.

6.2.7 It is preferred that all components are supplied and manufactured by companies under third party quality assurance schemes. However it is realised that in many instances this may be impractical.

Under these circumstances greater emphasis shall be placed on inspection. Examples could be fixings used in conjunction with a system. Variations in the materials used for the fixings could affect the performance.

6.2.8 Documented procedures shall be provided for the inspection of components when delivered to site.

6.2.9 Documented procedures shall be provided for the installation and final inspection of the system and labelling.

6.2.10 Documented procedures shall define appropriate actions if non-compliances are identified.

Record system

6.2.11 The quality system shall be such that a unique number from receipt of an order through to installation and inspection and subsequent maintenance identifies each project.

6.2.12 All component batches used in the installation phase shall be identified on a file relating to the project.

6.2.13 Details of all systems installed and subsequent maintenance shall be recorded in a logbook and on the project file together with the number/ID of the Certifire labels fixed to each installation.

6.2.14 The file must be retained for a minimum of ten years and be readily identified from the project reference.

Maintenance requirements

6.2.15 All fire protection systems require ongoing maintenance and inspection to maintain their performance at a level close to that of the original installation. The integrity of a barrier system can be impaired by disruption of seals or barriers by the installation of new services or relocation of existing services. The logbook shall identify the frequency and scope of inspections required and specifies procedures for the notification of building works and immediate reinstatement of penetration fire protection systems.

6.2.16 The requirements for inspection/ maintenance will vary with the building use, type of system and state regulations. Notwithstanding the above all systems should be inspected annually to ensure the fire protection systems remain in tact, and records shall be kept of these inspections and any works undertaken.

APPENDIX 1

LABELLING AND USE OF THE CERTIFIRE LOGO

A1.1 General

In order for an installation to be labelled with a Certifire label the system must comply with a Certifire certificate which was current at the time of installation and be installed by a Certifire listed contractor within the scope of the contractor's Certifire certificate.

A1.2 Labelling format

Labelling shall be obtained from Certifire Pty. Ltd.

Example label for Certifire listed installers for use on light weight fire resistant partitions:



The label size will be 100mm x 50mm.

A1.3 Location

Where practicable the label shall be either:

- on the wall; or
- mounted in the foyer or other 'public' areas in the area protected by the system, or
- mounted adjacent to manual call points if the positions are known, or
- adjacent to all fire exits from the area with light weight fire resistant partitions protected under the Certifire scheme

A1.4 Labelling methods

Certifire labels may be mechanically fixed or bonded in such a manner that accidental removal would be unlikely to occur.

A1.5 Packaging and Promotional literature

When a Certifire certificate has been issued to a company (manufacturer/supplier and installer) the company is entitled to use the Certifire mark shown below on packaging and/or promotional literature provided:

- a) the company may only use the mark or claim or imply certification in respect of products or services complying with the relevant performance, training and quality assessment schedules within the scope and limitations given in the certificate(s).
- b) copies of all material containing reference to certification and Certifire are submitted to Certifire for verification prior to publication and that any modifications required by Certifire are incorporated.